



NOTE:

- UNREINFORCED CONCRETE CAP IS TO BE SIZED BASED ON THE FOLLOWING DIMENSIONS:
- 6" THICK
 - LENGTH VARIES BASED ON DIA. OF CROSSING UTILITY PIPE (5' FROM THE OUTSIDE EDGE OF THE CROSSING UTILITY PIPE IN BOTH DIRECTIONS)
 - SEWER DIAMETER + 2' WIDE (EXTENDS 1' IN EITHER DIRECTION OVER THE SEWER PIPE); 3' MINIMUM

THE
METROPOLITAN SEWER DISTRICT
OF
GREATER CINCINNATI
**UNREINFORCED
CONCRETE CAP**

NO SCALE

DATE: OCT. 2023

APPROVED: *Nya Webb*
SEWERS CHIEF ENGINEER

M.C.

ACC. NO. 61307